

2021-09-07

**REQUEST FOR QUOTATION
EDUCATION CENTRE – WASHROOM UPGRADES
TZC T 03-2021-08
ADDENDUM #4**

This addendum shall be incorporated into, and form part of TZC T 03-2021-08 and take precedence over all requirements of the previously issued bid documents including plans. This addendum must be signed by the bidder (signing officer) in the appropriate space and must be attached to the Form for submission by the bidder. This Addendum consists of one (1) pages.

1. QUESTION:

Supplier says they only do up to 1/4 " for coloured plexiglass. Any higher, has to be clear. Drawings are asking for 1/2". Which do you prefer?

RESPONSE:

1/4" is acceptable in order to have colour.

2. QUESTION:

Note 6 on E7.1 lists siemens and square D as acceptable panel manufactures, we would like to ask if Eaton/Cutler hammer is also acceptable for the panel.

RESPONSE:

The panel must be Siemens or Square D manufactured. There are no allowable alternatives.

Receipt of the Addendum shall be acknowledged as part of your submission.

The Board of Management of the Toronto Zoo reserves the right to reject any or all Tenders or to accept any quotation, should it deem such action to be in its interests.

If you have any queries regarding this matter, please contact Mr. Peter Vasilopoulos, Supervisor, Purchasing & Supply, at 416-392-5916 or by email pvasilopoulos@torontozoo.ca.

Yours truly,

Peter Vasilopoulos
Supervisor, Purchasing & Supply

I/we hereby acknowledge receipt of this addendum and make allowance in my bid.

Signed (Must be Signing Officer of Firm)

Name of Firm _____

Date: _____